

* Sheathing

DuROCK Moisture Barrier

DuROCK Moisture Barrier/Adhesive

DuROCK PUCCS Insulation
with 10mm Geometrically Defined
Drainage Cavity (GDDC)

DuROCK Fibre Mesh
embedded in DuROCK Prep Coat

DuROCK Fibre Mesh
embedded in Moisture Bear

DuROCK Finish Coat

Back-wrapped Starter Mesh

DuROCK Uni-Track, drainage track
with lip

Minimum 50mm (2")
clearance required
above floor level

* Balcony floor

* Backer Rod at joint

* Backer Rod and Sealant

* Self-Adhering
Transition Membrane at joint

(* by others)

PUCCS-CHRC
(FOR COMMERCIAL AND HIGH RISE CONSTRUCTION)

DRAWING TITLE:

TERMINATION AT BALCONY SLAB
(ABOVE AND BELOW THE SLAB)

This detail complements the corresponding system specification and illustrates the system configuration for the depicted construction. Visit www.durock.com for the latest revisions and contact DuROCK for project-specific details to suit conditions other than those depicted. DuROCK assumes no liability for the architecture, design, engineering, or workmanship of any project.

DuROCK
Alfacing International Limited
101-B ROYTEC ROAD
WOODBRIDGE, ONTARIO
TEL : (905) 856-0133, FAX : (905) 856-9654
www.durock.com
ARCHITECTURAL FINISHING SYSTEMS

LAST REVISE: MAR 2017

ISSUED: MAY 2007

DRAWN BY: RIZ

SCALE: NTS

PUCCS-CHRC
D09