

- * Sheathing
- DuROCK Moisture Barrier
- DuROCK Moisture Barrier/Adhesive
- DuROCK PUCCS, EPS Insulation Board
- DuROCK Reinforcing Mesh embedded in DuROCK Prep Coat
- DuROCK Fibre Mesh embedded in Moisture Bear
- DuROCK Finish Coat
- Wrap insulation edge with reinforcing mesh, terminate base coat at drainage track
- DuROCK Uni-Track, drainage track with lip

* Balcony floor

Minimum 50mm (2")
clearance required
above floor level

* Backer Rod at joint

- * Backer Rod and Sealant
- Wrap insulation edge with mesh-reinforced base coat
- * Self-Adhering Transition Membrane at joint

(* by others)

DuROCK SYSTEM:
PUCCS-CHRC
 (FOR COMMERCIAL AND HIGH RISE CONSTRUCTION)

DRAWING TITLE:
TERMINATION AT BALCONY SLAB
 (ABOVE AND BELOW THE SLAB)

This detail complements the corresponding system specification and illustrates the system configuration for the depicted construction. Visit www.durock.com for the latest revisions and contact DuROCK for project-specific details to suit conditions other than those depicted. DuROCK assumes no liability for the architecture, design, engineering, or workmanship of any project.

DuROCK
 Alfacing International Limited
 101-B ROYTEC ROAD
 WOODBRIDGE, ONTARIO
 TEL : (905) 856-0133, FAX : (905) 856-9654
www.durock.com
 ARCHITECTURAL FINISHING SYSTEMS

LAST REVISION:	JAN 2019
ISSUED:	MAR 2007
DRAWN:	RIZ
SCALE:	NTS
PUCCS-CHRC	
D-09	